

## ***Annual Drinking Water Quality Report for 2023***

***Village of West Winfield  
179 South Street, P.O. Box308  
West Winfield, NY 13491***

***(Public Water Supply ID # NY2102342)***

### **INTRODUCTION**

To comply with State and Federal regulations, **the Village of West Winfield**, will be annually issuing a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. Last year, your tap water met all State drinking water health standards, with the exception of two reporting requirements. We failed to report sample results within the required timeframe. An explanation is contained within this report. We are proud to report that our system has never violated a maximum contaminant level or any other water quality statement. This report provides an overview of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards. If you have any questions about this report or concerning your drinking water, please contact **Scott VanDuren, Village Clerk, at (315) 822-3051**. We want you to be informed about your drinking water. If you want to learn more, please attend any of our regularly scheduled village board meetings. **The meetings are held on the 2<sup>nd</sup> Monday of each month at 6:30pm at Bisby Hall located at 179 South St., West Winfield, NY 13491.**

### **WHERE DOES OUR WATER COME FROM?**

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The State Health Department's and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Our water source is a groundwater source in the form of 2 wells. Our primary wells #3 and #4 is located south of State Route 20 within the Village limits and they are about sixty (60) feet deep. The water is chlorinated after being pumped from the wells and is then introduced into the distribution system. Any water that is not used by the consumers is stored in a 300,000 - gallon steel storage tank located northwest of the village. Our water system serves a population of 862 through 340 metered service connections.

### **SOURCE WATER ASSESSMENT**

At the time of this report the Source Water Assessment for the Village of West Winfield was not yet completed. Questions concerning the Source Water Assessment should be directed to the **NYSDOH / Herkimer District Office (315) 866-6879**.

### **ARE THERE CONTAMINANTS IN OUR DRINKING WATER?**

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include: total coliform, inorganic compounds, nitrate, nitrite, lead and copper, volatile organic compounds, and synthetic organic compounds. The table presented below depicts which compounds were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the **EPA's Safe Drinking Water Hotline (800-426-4791) or the NYSDOH – Herkimer District Office (315) 866-6879**.

Table of Detected Contaminants							
Contaminant	Violation Yes/No	Date of Sample	Level Detected (Average) (Range)	Unit Measurement	MCLG	Regulatory Limit (MCL, TT or AL)	Likely Source of Contamination
<b>Inorganics</b>							
Nitrate as N Well #3 Well #4	No	9/23	3.7 4.0	mg/l	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Barium Well #3 Well #4	No	9/27	0.0002 0.0002	mg/l	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Sulfate Well #3 Well #4	No	9/05	19.2 17.1	mg/l	N/A	250	Naturally occurring.
Lead (2)	No	10/23	0.0055 (0.0006-0.0103)	mg/l	N/A	AL = .015	Corrosion of household plumbing systems; Erosion of natural deposits.
Copper (1)	No	10/23	0.2443 (0.0425-0.3781)	mg/l	N/A	AL = 1.3	Corrosion of household plumbing systems; Erosion of natural deposits.; leaching from wood preservatives.
Chromium Well #3 Well #4	No	7/07 7/07	3.7 3.7	ug/l	100	100	Discharge from steel and pulp mills; Erosion of natural deposits.
Nickel Well #3 Well #4	No	9/27 9/27	0.001 0.001	ug/l	N/A	N/A	N/A
Sodium (4) Well #3 Well #4	No No	9/27 9/27	1.59 1.51	mg/l	N/A	see Health Effects (3)	Naturally occurring; Road salt.
<b>Synthetic Organics</b>							
Perfluorooctanoic acid (PFOA) (5)  Well #3  Well #4	No  No	1/23 9/23  1/23 9/23	0.852 0.707  ND 1.41	ng/l  ng/l	N/A  N/A	10  10	Released into the environment from widespread use in commercial and industrial applications.
Perfluorooctane sulfonic acid (PFOS) (6)  Well #3  Well #4	No  No	1/23 9/23  1/23 9/23	1.49 1.74  1.72 1.98	ng/l  ng/l	N/A  N/A	10  10	Released into the environment from widespread use in commercial and industrial applications.

Radiological							
Gross Beta	No	12/19	ND0.526 0 +/- 0.307	PCI/L	0	15	Decay of natural deposits and man-made emissions.
Gross Alpha	No	12/19	0.311 0 +/- 0.735	PCI/L	0	15	Erosion of natural deposits.
Radium – 228	No	8/10	-0.0599 +/- 0.289	PCI/L	0	5	Erosion of natural deposits.
Radon - 222	No	12/19	276.7 +/-40	PCI/L	0	5	Erosion of natural deposits.
Disinfection By-products							
Total Trihalomethanes (TTHM's)	No	19/23	10.32	Ug/l	N/A	80	By-product of drinking water chlorination needed to kill harmful organisms. TTHMs are formed when source water contains large amounts of organic matter.
HAA5 Haloacetic Acids, Total	No	19/23	ND	Ug/l	N/A	60	By-product of drinking water chlorination needed to kill harmful bacteria.
Chlorine Residual	No	Daily	0.71 (0.66-0.74)	Mg/l	T	4.0	By-product of drinking water chlorination

### Notes

1 – The level presented represents the 90<sup>th</sup> percentile of the 10 sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90<sup>th</sup> percentile is equal to or greater than 90% of the copper values detected at your water system. In this case, ten samples were collected at your water system and the 90<sup>th</sup> percentile value was the 0.30 mg/l). The action level for copper was not exceeded at any of the sites tested.

2 – The level presented represents the 90<sup>th</sup> percentile of the ten samples collected. The action level for lead was not exceeded at any of the 10 sites tested.

3 – This level represents the annual quarterly average calculated from data collected.

4 - Water with more than 20 mg/l of sodium should not be used by people on severely restricted sodium diets. Water containing more than 270 mg/l should not be used for drinking by people on moderately restricted sodium diets.

5 - PFOA caused a range of health effects when studied in animals at high exposure levels. The most consistent findings were effects on the liver and immune system and impaired fetal growth and development. Studies of high-level exposures to PFOA in people provide evidence that some of the health effects seen in animals may also occur in humans. The United States Environmental Protection Agency considers PFOA as having suggestive evidence for causing cancer based on studies of lifetime exposure to high levels of PFOA in animals.

6 - PFOS caused a range of health effects when studied in animals at high exposure levels. The most consistent findings were effects on the liver and immune system and impaired fetal growth and development. Studies of high-level exposures to PFOS in people provide evidence that some of the health effects seen in animals may also occur in humans. The United States Environmental Protection Agency considers PFOS as having suggestive evidence for causing cancer based on studies of lifetime exposure to high levels of PFOS in animals

### Definitions:

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**Non-Detects (ND)**: Laboratory analysis indicates that the constituent is not present.

**Nephelometric Turbidity Unit (NTU)**: A measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

**Milligrams per liter (mg/l)**: Corresponds to one part of liquid in one million parts of liquid (parts per million - ppm).

**Micrograms per liter (ug/l)**: Corresponds to one part of liquid in one billion parts of liquid (parts per billion - ppb).

**Nanograms per liter (ng/l)**: Corresponds to one part of liquid to one trillion parts of liquid (parts per trillion - ppt).

**Picograms per liter (pg/l)**: Corresponds to one part per of liquid to one quadrillion parts of liquid (parts per quadrillion – ppq).

**Picocuries per liter (pCi/L)**: A measure of the radioactivity in water.

**Millirems per year (mrem/yr)**: A measure of radiation absorbed by the body.

**Million Fibers per Liter (MFL)**: A measure of the presence of asbestos fibers that are longer than 10 micrometers.

### **WHAT DOES THIS INFORMATION MEAN?**

As you can see by the table, our system had no violations. We have learned through our testing that some contaminants have been detected; however, these contaminants were detected below the level allowed by the State.

### **IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?**

During 2023, the village water system received two notices of violation. Failure to submit secondary inorganic chemical water sample results by the 10<sup>th</sup> day of the month for the 1<sup>st</sup> and 3<sup>rd</sup> quarters. Results were submitted, but late. Otherwise, in 2023 our system met all the Rules and Regulations that govern Operations.

### **DO I NEED TO TAKE SPECIAL PRECAUTIONS?**

Although our drinking water met or exceeded state and federal regulations, some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbial pathogens are available from **the Safe Drinking Water Hotline (800-426-4791)**.

### **WHY SAVE WATER AND HOW TO AVOID WASTING IT?**

Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water:

- ◆ Saving water saves energy and some of the costs associated with both of these necessities of life;
- ◆ Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems and water towers; and
- ◆ Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions so that essential firefighting needs are met.

You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:

- ◆ Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get a run for your money and load it to capacity.
- ◆ Turn off the tap when brushing your teeth.
- ◆ Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it up an you can save almost 6,000 gallons per year.
- ◆ Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you save more than 30,000 gallons a year.
- ◆ Use your water meter to detect hidden leaks. Simply turn off all taps and water using appliances, then check the meter after 15 minutes, if it moved, you have a leak.

### **CLOSING**

Thank you for allowing us to continue to provide your family with quality drinking water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our customers. The costs of these improvements may be reflected in the rate structure. Rate adjustments may be necessary in order to address these improvements. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future. Please call our office if you have questions **at (315) 822-3051**.